

SUPPLEMENTAL/BID BULLETIN

Republic of the Philippines
Metals Industry Research and Development Center
Gen. Santos Ave., Bicutan, Taguig City 1631
Tel Nos. 837 0431 to 38 loc. 402; Fax No. 838 7876
Email: bac@mirdc.dost.gov.ph


ADDENDUM NO. 1

This Supplemental Bid Bulletin No. 1 is being issued to further clarify, modify and amend items, specifications in the Bid Documents to address key issues for the **“SUPPLY AND INSTALLATION OF TWO (2) UNITS FUMEHOOD, TWO (2) UNITS DUCTED CANOPY HOOD AT CHEMICAL LABORATORY AND THREE (3) UNITS DUCTED CANOPY HOOD WITH ENCLOSURE AT INSTRUMENTATION LABORATORY”**

SUPPLY AND INSTALLATION OF TWO (2) UNITS FUMEHOOD, TWO (2) UNITS DUCTED CANOPY HOOD AT CHEMICAL LABORATORY AND THREE (3) UNITS DUCTED CANOPY HOOD WITH ENCLOSURE AT INSTRUMENTATION LABORATORY	
FROM	TO
TERMS OF REFERENCE	
1. Time frame of 45 calendar days	1. Time frame of 60 calendar days
2. Service fixtures for gas and water with wash down system drainage.	2. Service fixture for gas and water with automatic wash down system drainage.
3. 8 inches fiber glass ducting and supports	3. 8 inches stainless steel 304 ducting and supports

This shall form an integral part of the Bidding Documents for the **“SUPPLY AND INSTALLATION OF TWO (2) UNITS FUMEHOOD, TWO (2) UNITS DUCTED CANOPY HOOD AT CHEMICAL LABORATORY AND THREE (3) UNITS DUCTED CANOPY HOOD WITH ENCLOSURE AT INSTRUMENTATION LABORATORY”**

For the guidance and information of all concerned.


MS. AUREA T. MOTAS
BAC Chairman
Metals Industry Research and Development Center