

SUPPLEMENTAL/BID BULLETIN

Republic of the Philippines
Metals Industry Research and Development Center
Gen. Santos Ave., Bicutan, Taguig City 1631
Tel Nos. 837 0431 to 38 loc. 443 or 444;
Email: bac@mirdc.dost.gov.ph

ADDENDUM NO. 1


This Supplemental Bid Bulletin No. 1 is being issued to further clarify, modify and amend items, specifications in the Bid Documents to address key issues for the “**PROCUREMENT OF ONE (1) LOT SUPPLY, DELIVERY, INSTALLATION OF PRECISION AIR CONDITIONING UNIT (PACU) WITH ENVIRONMENTAL MONITORING SYSTEM AND FIRE SUPPRESSION SYSTEM FOR MIRDC DATA CENTER**”

FROM	TO
<p>SCOPE OF WORK</p> <p>MAINTENANCE AND SUPPORT</p> <ul style="list-style-type: none">All equipment supplied (such as Precision Air Conditioning Unit and mechanical/electrical installations & all requested accessories) shall undergo semi-annual preventive maintenance to ensure proper operation. All contract work shall be performed by the manufacturer’s factory trained service personnel.	<p>MAINTENANCE AND SUPPORT</p> <ul style="list-style-type: none">All equipment supplied (such as Precision Air Conditioning Unit and mechanical/electrical installations & all requested accessories) shall undergo quarterly preventive maintenance to ensure proper operation.
<p>OTHER REQUIREMENTS</p> <ul style="list-style-type: none">Manufacturer of offered brand must have locally based customer care center in the Philippines with local hotline number to ensure quality of support and same time zone. Service representative must speak local language. Certification from the Manufacturer must be provided as proof of documents in this requirementThe brand offered shall be available in Philippine Market for at least ten (10) years and must have local representative office in the Philippines.	<p>OTHER REQUIREMENTS</p> <ul style="list-style-type: none">Manufacturer of offered PACU brand must have locally based customer care center in the Philippines with local hotline number to ensure quality of support and same time zone. Service representative must speak local language. Certification from the Manufacturer must be provided as proof of documents in this requirementThe PACU brand offered shall be available in Philippine Market for at least ten (10) years and must have local representative office in the Philippines
<p>SITE INSPECTION</p>	<p>Bidders are required to have a prior site inspection before the bid submittal to ensure of their offered solution. Only bidders who conducted a site visit prior to the submission of bids will be accepted, to ensure that the bid submitted conforms to the Terms of Reference</p>

	and the site condition. Ocular can be conducted until December 20, 2021.
--	--

This shall form an integral part of the Bidding Documents for the **'PROCUREMENT OF ONE (1) LOT SUPPLY, DELIVERY, INSTALLATION OF PRECISION AIR CONDITIONING UNIT (PACU) WITH ENVIRONMENTAL MONITORING SYSTEM AND FIRE SUPPRESSION SYSTEM FOR MIRDC DATA CENTER'**

For the guidance and information of all concerned.


MS. MERCEDITA G. ABUTAL
BAC Chair
Metals Industry Research and Development Center